



DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS

Robert Copis made  
2-14-97 Public Safety Services  
ca



V. J. BELLA  
STATE FIRE MARSHAL

MIKE FOSTER, JR.  
GOVERNOR

MEMORANDUM

TO: REVIEW STAFF/INSPECTION STAFF/FIRE ALARM CONTRACTORS  
FROM: JERRY JONES  
CHIEF ARCHITECT  
RE: VISUAL NOTIFICATION IN CHURCHES AND PRIVATE CLUBS  
DATE: JULY 8, 1997

There seems to be a lot of confusion concerning the requirements for visual notification for churches and private clubs; or church owned and operated establishments (i.e. daycare at a church), since the release of the March 6, 1997 memorandum exempting those types of facilities from the ADA.AG requirements for visual notification. Please be advised that these facilities are not required to comply with the requirements for strobe placement in accordance with NFPA 72. If any strobes are provided, then the fire alarm system exceeds the minimum requirements of the code.

JWJ/MCM/kmw

cc: Jerry W. Jones  
Henry C. Reed, Sr.

VISUAL

5074

"Is Yours Working" ??

Smoke Detectors Save Lives !!

OFFICE OF STATE FIRE MARSHAL • 5150 FLORIDA BOULEVARD, BATON ROUGE, LA 70806  
(504) 925-4911 1-800-256-5452