



STATE OF LOUISIANA
DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS

OFFICE OF STATE FIRE MARSHAL

EDWIN W. EDWARDS
GOVERNOR

COL. PAUL W. FONTENOT
DEPUTY SECRETARY

October 2, 1995

12.568
Donald F. Mobley
Manager of Quality Control and Regulatory Affairs
GILES FOODSERVICE EQUIPMENT
P. O. Box 210247
Montgomery, AL 36121-0247

RE: Giles Ventless Hood Models "FSH-2" & "FSH-5", Acceptability
Determination for Use Within Louisiana

Dear Mr. Mobley:

This is to advise that we have reviewed the product literature and Underwriters Laboratories Listing Report for the Giles Ventless Hood and have determined that the ventless hoods are acceptable for use within Louisiana subject to the following stipulations:

- 11/11/95
1. The ventless hood shall be installed over UL listed cooking appliances under the limitations specified in the UL classification markings for fryers and ovens.
 2. The hood shall only be used to protect a maximum of two fryers. The total cooking service areas of both fryers shall not exceed 380 square inches.
 3. The hood shall be protected with a wet chemical fire suppression system installed in accordance with NFPA 96 and UL 300 Test Standards.
 4. The hood shall be installed in accordance with the clearances shown on the supplemental marking provided with the hood.
 5. A pressure differential type interlock system shall be installed in the unit in order to prevent the hood and the cooking appliance from operating if any filter is clogged or missing.
 6. Cleaning instructions with operating instructions shall be included with each shipped unit. The installation of these products shall comply with all the installation provisions of Chapter 10 of NFPA 96, 1994 Edition.
 7. Only UL listed grease filter and UL Class I air filters shall be used in this unit.
 8. There shall be kept on premises a cleaning/maintenance log for the ventless hood and filter system.
- 1095

5150 FLORIDA BOULEVARD, BATON ROUGE, LA 70806
(504) 925-4911 1-800-256-5452