





## MEMORANDUM

MIKE" FOSTER, JR.

TO: ARCHITECTURAL REVIEW STAFF

FROM: HENRY C. REED, SR. ARCHITECT SUPERVISQ

RE: OIL CHANGE PITS

DATE: OCTOBER 7, 1997

The following review procedures shall apply to oil change pits. Based on a review of various requirements such as 30A:5-1.2, 101:28-2.4.1 and 101:28-2.5.3, it was determined that if an occupant can reach a first floor exit within 50 feet from any point in the pit, then the pit is not required to be provided with an enclosed exit at that level. Most oil change pits will fall within this category, if not, cite the enclosed exit requirement.

HCR/kmw

cc: Jerry W. Jones Pat Slaughter

2106

"Is Yours Working" ?? Smoke Detectors Save Lives II OFFICE OF STATE FIRE MARSHAL • 5150 FLORIDA BOULEVARD, BATON ROUGE, LA 70806 (504) 925-4911 1-800-256-5452

DPSFM 7000