DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS

Public Safety Services

M. J. "MIKE" FOSTER, JR. GOVERNOR



RECEIVED

September 18, 1996

Mike Remakel Special Projects Manager H & K DALLAS INC P. O. Box 180729 Dallas, TX 75218

SEP 2 3 1996

OFFICE OF STATE FIRE MARSHAL NEW ORLEANS DISTRICT NEW ORLEANS

New McDonald's Restaurant Within the State of Louisiana RE:

SUBJ: Fire Suppression Systems for Kitchen Exhaust Hood Placement of Extinguishing Agent and Expellant Gas Cylinders Within 3' of Cooking Appliances

Dear Mr. Remakel:

This is to advise that we have reviewed the information provided in and with your letter of September 11, 1996 in which you have requested that this office allow the stainless steel cylinder enclosures/chase to be considered an element of protection for the extinguishing agent/expellant gas assemblies in lieu of the 3' separation general rule utilized by this office. As you are aware, the standards require that the extinguishing agent and expellant gas assemblies be located such that they will not be affected by a fire occurring on the protected appliance. The code, in fact, does not require a 3' separation . That a distance imposed by this office as a general rule.

After taking into consideration the documentations provided in and with your letter of September 11, 1996, it has been determined that the stainless steel chase enclosure for the agent /expellant gas cylinders will provide a level of protection equal to that provided by a 3' distance separation. Therefore, be advised that this office will hereby grant your request.

If you should have further questions or need additional clarifications, please feel free to contact this office.

Sincerely,

Jone Jetty ef Architect

JWJ/adg

cc: Patricia Slaughter

Copy to deputies 9.24.96 mgm

1075

"Is Yours Working" ?? Smoke Detectors Save Lives !! OFFICE OF STATE FIRE MARSHAL • 5150 FLORIDA BOULEVARD, BATON ROUGE, LA 70806 (504) 925-4911 1-800-256-5452

DPSEM 7000