MEMORANDUM

To: Fire Extinguisher Contractors/State Fire Marshal Personnel

Originally From: Jerry W. Jones - Deputy Assistant Secretary/Chief Architect

Revised By: Don Zeringue – Chief Architect

Subject: Apartment Fire Extinguishers-Size/Location/Mounting

Date: July 6, 1998 – Revised March 17, 2005 (Note: Bold print revision Pursuant to NFPA 101:Table 3-2.1, Maximum floor area for unit of "A")

This is to advise that we have reviewed several requests for clarification of the requirements for the provision of fire extinguishers in apartment buildings, and have made the following observations and determination.

As you know, NFPA 10 establishes specific requirements for mounting, sizing, and locating fire extinguishers. This office will allow a deviation from the specific requirements of NFPA 10 in order to address the unique problem apartment owners have regarding the theft of fire extinguishers typically required to be installed in common areas. If the apartment owner (not the manager) submits a written request for permission to deviate from the specific requirements of NFPA 10, this office will allow the installation of 1A:10B:C fire extinguishers inside each apartment **not exceeding 1,500 sq. ft.** in lieu of installing 2A:10B:C fire extinguishers in the common areas throughout the apartment complex. These smaller extinguishers shall be wall mounted near the kitchen or mounted inside the cabinet under the kitchen sink. Owners who wish to request permission to deviate from the specific requirements of NFPA 10 shall submit their request in writing to the Fire Marshal District Inspection Office responsible for the building's location. The letter must identify the building location and the licensed fire extinguisher company certifying the extinguishers.

If you have any questions regarding this procedure, please contact the District Inspection Office for your area.

Baton Rouge (225) 925-4914 Lafayette (337) 886-1273 New Orleans (504) 568-5500 Shreveport (318) 676-1745

JWJ/HCR/DZ/kmw/md